



EVPÜ

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0086

of June 11, 2008

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Fire detection and fire alarm systems Interactive addressable fire alarm panel

IFS 7002 it receives and evaluates signals from detectors, signaling and transmitting informations about it's actual position, and it controls fire detection and fire alarm systems connecting equipments, servient to limiting of fire extension; is intended for power supply of control and indicating equipment and has declared a compatibility with it

placed on the market by

UniPOS Ltd.

Grenaderska Str. 114, 5800 Pleven, Bulgaria

and produced in the factory

UniPOS Ltd.

Grenaderska Str. 114, 5800 Pleven, Bulgaria

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÜ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-2: 1997 + AC: 1999/A1: 2006

EN 54-4: 1997 + AC: 1999/A1: 2002

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on June 11, 2008 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Karol Glamoš

The



marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

020487

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic. www.evpu.sk